

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7271-0026:305 Page 1 of 1

**CATEGORY:** Ionization Smoke Detector

**LISTEE:** Simplex, 100 Simplex Drive, Westminster, MA 01441-0001  
Contact: Paul Mattern (978) 731-8542 \*Fax (978) 731-8881

**DESIGN:** Model 612I ionization type, conventional smoke detector. Refer to listee's data sheet for additional detailed product description, electrical rating and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. Units are also suitable for installation in high attitudes up to 9000 ft.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as smoke detectors for use with Models M612/912, 4B or 6B base (CSFM Listing No. 7300-1493:181) and separately listed compatible fire alarm control units.

**XLf:** 7271-1532:103

**NOTE:** Formerly 7271-1493:180

\*Rev. 06-06-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 17, 2004**

*Listing Expires **June 30, 2005***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager